

Public Service Electric & Gas Company, Docket No. 50-354, Hope Creek Generating Station, Salem County, New Jersey

Date of applications for amendment: November 30, 1994 and March 30, 1995, as supplemented by letter dated September 5, 1995.

Brief description of amendment: The change to TS Table 3.3.1-2, "Reactor Protection System Response Times," TS Table 3.3.2-3, "Isolation System Instrumentation Response Time," TS Table 3.3.3-3, "Emergency Core Cooling System Response Times," and associated Bases, eliminates the requirement to perform response time testing for certain classes of equipment and transfers the requirements of the above-referenced TS Tables to the Updated Final Safety Analysis Report.

Date of issuance: October 24, 1995

Effective date: As of date of issuance, to be implemented within 60 days.

Amendment No.: 85

Facility Operating License No. NPF-57: This amendment revised the Technical Specifications.

Date of initial notice in Federal Register: March 29, 1995 (60 FR 16198 and August 16, 1995 (60 FR 42606) The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated October 24, 1995. No significant hazards consideration comments received: No

Local Public Document Room

location: Pennsville Public Library, 190 S. Broadway, Pennsville, New Jersey 08070

Union Electric Company, Docket No. 50-483, Callaway Plant, Unit 1, Callaway County, Missouri

Date of application for amendment: May 20, 1994, as supplemented on March 29, 1995

Brief description of amendment: The amendment revises Technical Specifications to implement the NRC's Final Policy Statement on Technical Specification Improvements for Nuclear Power Reactor by relocating specifications that do not meet policy statement criteria to the Final Safety Analysis Report.

Date of issuance: October 20, 1995

Effective date: Immediately, to be implemented within 120 days.

Amendment No.: 103

Facility Operating License No. NPF-30. Amendment revises the Technical Specifications.

Date of initial notice in Federal Register: August 31, 1994 (59 FR 45036). The March 29, 1995, letter provided supplemental information that did not change the initial proposed no

significant hazards consideration determination or expand the scope of the original Federal Register notice.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated October 20, 1995. No significant hazards

consideration comments received: No

Local Public Document Room

location: Callaway County Public Library, 710 Court Street, Fulton, Missouri 65251

Wisconsin Electric Power Company, Docket Nos. 50-266 and 50-301, Point Beach Nuclear Plant, Unit Nos. 1 and 2, Town of Two Creeks, Manitowoc County, Wisconsin

Date of application for amendments: January 26, 1994, as supplemented by letters dated December 1, 1994, and June 23, 1995

Brief description of amendments: These amendments revise Technical Specification (TS) Section 15.3.0, "General Considerations." This section specifies the actions to be taken for conditions not directly addressed in the action statements for the TSs. In addition, changes to the applicable bases (including the bases for TS 15.3.3) and editorial changes are also included.

Date of issuance: October 12, 1995

Effective date: October 12, 1995

Amendment Nos.: 163 and 167

Facility Operating License Nos. DPR-24 and DPR-27: Amendments revised the Technical Specifications.

Date of initial notice in Federal Register: March 16, 1994 (59 FR 12373) The December 1, 1994 and June 23, 1995, submittals provided supplemental information that did not change the initial proposed no significant hazards consideration determination.

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated October 12, 1995. No significant hazards

consideration comments received: No

Local Public Document Room

location: Joseph P. Mann Library, 1516 Sixteenth Street, Two Rivers, Wisconsin 54241

Wisconsin Electric Power Company, Docket Nos. 50-266 and 50-301, Point Beach Nuclear Plant, Unit Nos. 1 and 2, Town of Two Creeks, Manitowoc County, Wisconsin

Date of application for amendments: April 17, 1995

Brief description of amendments: These amendments change TS Sections 15.6.2, "Organization," and 15.6.3, "Facility Staff Qualifications." The requirement for the Operations Manager to hold an NRC Senior Reactor Operator's (SRO) license has been

changed to provide additional staffing flexibility.

Date of issuance: October 12, 1995

Effective date: October 12, 1995

Amendment Nos.: 164 and 168

Facility Operating License Nos. DPR-24 and DPR-27. Amendments revised the Technical Specifications.

Date of initial notice in Federal Register: May 23, 1995 (60 FR 27346). The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated October 12, 1995. No significant hazards consideration comments received: No

Local Public Document Room

location: Joseph P. Mann Library, 1516 Sixteenth Street, Two Rivers, Wisconsin 54241

Dated at Rockville, Maryland, this 1st day of November 1995.

For the Nuclear Regulatory Commission
Jack W. Roe,

*Director, Division of Reactor Projects - III/
IV, Office of Nuclear Reactor Regulation*
[Doc. 95-27543 Filed 11-7-95; 8:45 am]

BILLING CODE 7590-01-F

[Docket Nos. 50-390 and 50-391]

Tennessee Valley Authority; Availability of Safety Evaluation Report Supplement Related to the Operation of Watts Bar Nuclear Plant, Units 1 and 2

The U.S. Nuclear Regulatory Commission has published the Safety Evaluation Report, Supplement 18 (NUREG-0847, Supp. 18) related to the operation of Watts Bar Nuclear Plant, Units 1 and 2, Docket Nos. 50-390 and 50-391.

Copies of the report have been placed in the NRC's Public Document Room, the Gelman Building, 2120 L Street NW., Washington, D.C. 20555, and in the Local Public Document Room, Chattanooga-Hamilton Library, 1001 Broad Street, Chattanooga, Tennessee 37402, for review by interested persons. Copies of the report may be purchased from the Superintendent of Documents, U.S. Government Printing Office, Post Office Box 37082, Washington, D.C. 20013-7082. GPO deposit account holders may charge orders by calling 202-512-2249 or 2171. Copies are also available from the National Technical Information Service, 5285 Port Royal Road, Springfield, Virginia 22161.

Dated at Rockville, Maryland this 31st day of October 1995.

For the Nuclear Regulatory Commission.
Peter S. Tam,
*Senior Project Manager, Project Directorate
II-3, Division of Reactor Projects—I/II Office
of Nuclear Regulatory Commission.*
[FR Doc. 95-27626 Filed 11-7-95; 8:45 am]
BILLING CODE 7590-01-P

[Docket No. 40-8838]

**Jefferson Proving Ground, Madison,
IN; Consideration of an Amendment
Request**

AGENCY: Nuclear Regulatory
Commission.

ACTION: Notice of Consideration of an
Amendment Request for Release of the
Remediated Portion of Jefferson Proving
Ground (JPG), Madison, IN, for
Unrestricted Use and Amendment of the
U.S. Army Source Material License
Number SUB-1435, and Opportunity for
Hearing.

The U.S. Nuclear Regulatory
Commission is considering two license
amendment requests for Source Material
License SUB-1435, issued to the U.S.
Army, Jefferson Proving Ground (JPG),
Madison, IN. The first amendment
would release, for unrestricted use, a
portion of JPG. The second amendment
would transfer the license from the U.S.
Army at JPG to the U.S. Army Test and
Evaluation Command (TECOM),
Aberdeen, MD.

The first amendment request involves
that portion of JPG which has been
remediated to levels in compliance with
the current NRC decommissioning
criteria for unrestricted release (i.e.,
"Guidelines for Decontamination of
Facilities and Equipment Prior to
Release for Unrestricted Use or
Termination of Licenses for Byproduct,
Source, or Special Nuclear Material,"
August 1987). This portion of the JPG
site is located south of the firing line. In
a letter dated September 14, 1995, the
licensee requested amendment of its
license to release the area south of the
firing line for unrestricted use. In
support of this request, the licensee
remediated the area south of the firing
line and submitted a final survey report.
In addition, the Army has submitted a
certificate of disposition which
indicated that the depleted uranium
(DU) material, that resulted from the
remediation activities, was disposed of
at a licensed burial site. Subsequently,
the NRC conducted a confirmatory
radiological survey of that area and
submitted the results of that survey to
the Army on September 27, 1995
(Report No. 040-08838/95001/R-III).
The radiological survey data in these
two reports (final and confirmatory

survey reports) did not identify any
radioactive material in excess of the
current NRC decommissioning criteria
for unrestricted use. Therefore, in
accordance with NRC regulations in 10
CFR 40.41, and NRC's Action Plan to
Ensure Timely Cleanup of Site
Decommissioning Management Plan
Sites (57 FR 13389, April 16, 1992), that
portion of JPG site would be released for
unrestricted use.

The second amendment request
involves the transfer of the license. The
U.S. Army has ceased its function as a
test center for DU projectiles and has
closed JPG effective September 30, 1995.
The Army has transferred certain DU
material to other Army locations under
different licenses. Therefore, the Army
currently possesses only the DU
material remaining onsite (estimated
80,000 kilograms), in the DU impact
area north of the firing line, and will not
conduct any further DU test activities at
JPG. As a result of these changes, the
Army has requested (in a letter dated
September 14, 1995) an amendment to
transfer the license to the U.S. Army
TECOM Headquarters in Aberdeen, MD.
Consequently, NRC is considering the
Army's request to amend the license to
conform with the current conditions
and status at JPG. In addition, NRC is
proceeding with the development of an
environmental impact statement (EIS)
which will examine alternatives for the
decommissioning of the remaining
radiologically contaminated portion of
JPG (i.e., the DU impact area north of
the firing line). A notice of intent to
develop an EIS was published in the
Federal Register on April 10, 1995 (60
FR 18155).

The NRC hereby provides notice that
this is a proceeding on an application
for a license amendment falling within
the scope of Subpart L, Informal Hearing
Procedures for Adjudication in
Materials Licensing Proceedings, of
NRC's rules and practices for domestic
licensing proceedings in 10 CFR Part 2.
Pursuant to § 2.1205(a), any person
whose interest may be affected by this
proceeding may file a request for a
hearing in accordance with § 2.1205(c).
A request for hearing must be filed
within (30) days of the date of
publication of this Federal Register
notice.

The request for a hearing must be
filed with the Office of the Secretary
either:

1. By delivery to the Docketing and
Service Branch of the Office of the
Secretary at One White Flint North,
11555 Rockville Pike, Rockville, MD
20852-2738; or
2. By mail or telegram addressed to
the Secretary, U.S. Nuclear Regulatory

Commission, Washington, DC 20555.
Attention: Docketing and Service
Branch.

In accordance with 10 CFR
§ 2.1205(e), each request for a hearing
must also be served, by delivering it
personally or by mail, to:

1. The applicant, U.S. Army Test and
Evaluation Command, Aberdeen
Proving Ground, Maryland 21005-5055,
ATTN: Ms. Tanya Palmateer Oxenberg,
and

2. The NRC staff, by delivery to the
Executive Director for Operations, One
White Flint North, 11555 Rockville
Pike, Rockville, MD 20852, or by mail,
addressed to the Executive Director for
Operations, U.S. Nuclear Regulatory
Commission, Washington, DC 20555.

In addition to meeting other
applicable requirements of 10 CFR Part
2 of the NRC's regulations, a request for
a hearing filed by a person other than
an applicant must describe in detail:

1. The interest of the requestor in the
proceeding;
2. How that interest may be affected
by the results of the proceeding,
including the reasons why the requestor
should be permitted a hearing, with
particular reference to the factors set out
in § 2.1205(g);
3. The requestor's areas of concern
about the licensing activity that is the
subject matter of the proceeding; and
4. The circumstances establishing that
the request for a hearing is timely in
accordance with § 2.1205(c).

For further details with respect to this
action, the application for the license
amendment is available for inspection at
the Commission's Public Document
Room, 2120 L Street NW., Washington,
DC 20555. If you have any questions or
comments about the requests, please
contact NRC's project manager for the
site, Dr. Bobby Eid, at telephone number
(301) 415-5811 or at Mail Stop T7F27,
U.S. NRC, Washington, DC 20555.

Dated at Rockville, Maryland this 31st day
of October 1995.

For the U.S. Nuclear Regulatory
Commission.

Michael F. Weber,

*Chief, Low-Level Waste and Decommissioning
Projects Branch, Division of Waste
Management, Office of Nuclear Material
Safety and Safeguards.*

[FR Doc. 95-27623 Filed 11-7-95; 8:45 am]

BILLING CODE 7590-01-P